### Validator Provided

### Appendix B

**Audit Information:** Certified Validation Report Template, Part A: Provided by Validator

Water Supplier Name: Lake Arrowhead CSD

PWS ID: 3610005

System Type: Potable

Audit Period: FY 2017/18

Utility Representation: Kellie Terrett (Accounting Technician), Marc Lippert (Operations Water Treatment Supervisor)

Validation Date: 10/17/2018

Call Time: Multiple

Sufficient Supporting Documents Provided: Yes

# Validation Findings & Confirmation Statement:

## **Key Audit Metrics**

Data Validity Score: 64 Data Validity Band (Level): Band III (51-70)

Real Loss: 179.636

Apparent Loss: 9.124

Non-revenue water as percent of cost of operating system: 14.6

## Certification Statement by Validator

California Water Code Section 10608.34 This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. oximes

If not, rejected recommendations are included here.

## Validator Information:

Water Audit Validator: Mark Lopez

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

# Certified Validation Report Template, Part B: Provided by Utility

Water Supplier Name: Lake Arrowhead Community Services District Water Supplier ID Number: CA3610005

Water Audit Period: FY 2017/18

# Water Audit & Water Loss Improvement Steps:

water audit: Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated

- Identify steps to improve source meter for accuracy.
- Random testing of customer meters for accuracy.

## Certification Statement by Utility Executive:

in their manual, Water Audit and Loss Control Programs, Manual M36, Fourth Edition and in the Free Water Audit Software version 5 Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water

Executive Name (Print)
Catherine Cerri

Executive Position General Manger

Date 10/17/2018